

Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

8620 *Driver Entry Terminal* NI / I / 2 / CD / T4; -40 °C \leq Ta \leq 70°C; NEMA Type 3R NI / I / 2 / IIB / T4; -40 °C \leq Ta \leq 70°C;

Equipment Ratings:

Nonincendive for use in Class I, Division 2, Groups C & D, and Class I, Zone 2, Group IIB, Hazardous (Classified) Locations with NEMA Type 3R

FM Approved for:

Varec Inc. Norcross, GA



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

| Class 3600 | 2011 |
|------------------|------|
| Class 3611 | 2004 |
| Class 3810 | 2005 |
| ANSI/ISA 61010-1 | 2004 |
| ANSI/NEMA 250 | 1991 |
| | |

Original Project ID: 3039261

Approval Granted: October 1, 2012

Subsequent Revision Reports / Date Approval Amended

Report Number

Date

Report Number

Date

121009

October 22,2012

FM Approvals LLC

J.E. Marquedant

Group Manager, Electrical

27 October 2012 Date