



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

8620 Driver Entry Terminal

NI / I / 2 / CD / T4; $-40\text{ }^{\circ}\text{C} \leq T_a \leq 70\text{ }^{\circ}\text{C}$; Type 3R

Equipment Ratings:

Nonincendive for use in Class I, Division 2, Groups C & D, Hazardous (Classified) Locations with Type 3R

FM Approved for:

Varec Inc.
Norcross, GA



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

CSA C22.2 No. 213	R2004
CSA C22.2 No. 1010-1	2004
ANSI/NEMA 250	1991


Original Project ID: 3039261

Approval Granted: October 1, 2012

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
121009	October 22, 2012		

FM Approvals LLC



J.E. Marquedant
Group Manager, Electrical

22 October 2012
Date